

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5276-0899:0121 Page 1 of 1

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: Universal Security Instruments 11407-A Cronhill Dr., Owings Mills, MD 21117
Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218
Email: steveb@universalsecurity.com

DESIGN: Models "Universal Security" MCN105, MCN105L and "USI Electric" MCN108, MCN108L single/ multiple station carbon monoxide alarms. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 Vac with the following back-up battery replacement:
Models MCN105 and MCN108 - 9Vdc Energizer 522, Duracell MN1604 or Zeus 9V
Models MCN105L and MCN108L -9Vdc Ultralife U9VL-J, U9VL-J-P or Energizer LA522

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Trade name "USI Electric", model number, electrical rating, and ETL label.

APPROVAL: Listed as single/ multiple station Carbon Monoxide alarms for residential applications. Refer to listee's Installation Instructions Manual for details.

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

08-06-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division